

Diesel Generator Sales, Installation, Hire, Spares, Service & Refurbishment



Certificate No: 1152

PLANT No: YP340

YP Plant No:	YP340				
KVA:	230				
Assembled by:	FG Wilson				
Year of Manufacture:	1995		ATTENDED TO THE PARTY OF THE PA	100	
Number of Hours:	714		ALIES V		
Engine make:	Perkins			MODEL :	1306E87TA(300)
Engine serial no:	TBC				
Engine type:	6 Cylinder turbocharged water cooled diesel				
Alternator make:	Newage Stamford			MODEL:	HC44B
Alternator serial no	C066258/04			FRAME:	Open
Alternator type:	Brushless			RATING:	Continuous
:	KVA	230		•	PRIME
:	KW	184			PRIME
	KVA	255			STANDBY
:	KW	204			STANDBY
:	VOLTS	415/240			
:	CYCLES	1500			
:	AMPS	319			
:	PHASE	3			
Control panel:	The unit is fitted with a F G Wilson 2001 analogue control panel which is a set mounted control panel arranged for remote start operation complete with monitoring for battery volts, hours clock, water temperature, oil pressure, frequency, amps and alternator volts.				

SPECIFICATION SHEET

Registered Office: Yorpower Limited Unit 2 Hurricane Close Sherburn In Elmet LS25 6PB UNITED KINGDOM

DIMENSIONS:

General

PRICE:



2953MML X 1003MMW X 1717MMH 2520KGS

mounted output circuit breaker and base fuel tank

Please enquire for quotation EX-WORKS + VAT

temperature and over speed.

Protections and automatic shutdown are provided for Low oil pressure, high engine

Ex standby F G Wilson unit in exceptional original condition with set mounted control, set

T: +44 (0) 1977 688155